



Number	20GR0434/01	Replaces	20GR0434/00
Issue date	28-01-2021	Contract number	E8090
Due date	28-01-2031	Module	B (Type testing)
Report number	190701988	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063DL3988		

EU TYPE EXAMINATION CERTIFICATE (GAR)

Kiwa hereby declares that the condensing central heating boilers, type(s):

**Thema Condens 31-CS/1 (N-DZ),
Thema Condens 31-CS/1 (N-INT),
Thema Condens 35-CS/1 (N-IR),
Thema Condens AS 30-CS/1 (N-INT),
ThemaFast Condens MA 30-CS/1 (N-INT)**

Manufacturer **Saunier Duval
Nantes, France**

meet(s) the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard: EN 15502-1:2012+A1:2015 and EN 15502-2-1-2012+A1:2016

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

CERTIFICATE



Number	20GR0434/01	Replaces	20GR0434/00
Issue date	28-01-2021	Contract number	E8090
Due date	28-01-2031	Module	B (Type testing)
Report number	190701988	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063DL3988	Page	1 of 2

APPENDIX TO EU TYPE EXAMINATION CERTIFICATE (GAR)

Manufacturer:
Saunier Duval

Types:

Model name	Heat input (G20)		Heat input (G31)	
	CH (kW - Hi)	DHW (kW - Hi)	CH (kW - Hi)	DHW (kW - Hi)
Thema Condens 31-CS/1 (N-DZ)	3,6 – 25,5	3,6 – 31,0	8,2 – 25,5	8,2 – 31,0
Thema Condens 35-CS/1 (N-IR)	3,6 – 30,6	3,6 – 34,8	8,2 – 30,6	8,2 – 34,8
Thema Condens AS 30-CS/1 (N-INT)	4,1 – 30,6	4,1 – 34,8	8,2 – 30,6	8,2 – 34,8
Thema Condens 31-CS/1 (N-INT)	3,6 – 25,5	3,6 – 31,0	8,2 – 25,5	8,2 – 31,0
ThemaFast Condens MA 30-CS/1 (N-INT)	3,6 – 25,5	3,6 – 31,0	8,2 – 25,5	8,2 – 31,0

Model name	Appliance categories		Countries
Thema Condens 31-CS/1 (N-DZ)	II _{2H3P}	G20 – 20 mbar G31 – 37 mbar	Algeria
Thema Condens 35-CS/1 (N-IR)	II _{2H3P}	G20 – 20 mbar G31 – 37 mbar	Iran
Thema Condens AS 30-CS/1 (N-INT)	PT: I _{2N} , I _{3P} LT: II _{2H3P} HU: II _{2HS3P}	G20 – 20 mbar HU: G20 – 25 mbar G25.1 – 25 mbar G31 – 37 mbar	Portugal Lithuania Hungary
Thema Condens 31-CS/1 (N-INT)	II _{2H3P}	G20 – 20 mbar G31 – 37 mbar	Lithuania Tunisia
ThemaFast Condens MA 30-CS/1 (N-INT)	I _{2N} , I _{3P}	G20 – 20 mbar G31 – 37 mbar	Portugal

Model name	Appliance types	Flue installation manuals (use latest version)
Thema Condens 31-CS/1 (N-DZ)	C ₁₃ , C ₃₃ , C ₄₃ , C ₅₃ , C ₈₃ , C ₉₃	0020294219 0020294218
Thema Condens 35-CS/1 (N-IR)	B ₂₃ , B ₃₃ , B ₅₃ , B _{53P} , C ₁₃ , C ₃₃ , C ₄₃ , C ₅₃ , C ₈₃ , C ₉₃	0020297386
Thema Condens AS 30-CS/1 (N-INT)	PT: C ₁₃ , C ₃₃ , C ₄₃ , C ₅₃ , C ₈₃ , C ₉₃ LT: B ₂₃ , B ₃₃ , B _{53P} , C _{13(X)} , C _{33(X)} , C _{43(X)} , C _{53(X)} , C _{83(X)} , C _{93(X)} HU: B _{23P} , C ₁₃ , C ₃₃ , C ₄₃ , C ₅₃ , C ₈₃ , C ₉₃	PT: 0020294228 LT: 0020294229 HU: 0020294233



Number	20GR0434/01	Replaces	20GR0434/00
Issue date	28-01-2021	Contract number	E8090
Due date	28-01-2031	Module	B (Type testing)
Report number	190701988	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063DL3988	Page	2 of 2

APPENDIX TO EU TYPE EXAMINATION CERTIFICATE (GAR)

Thema Condens 31-CS/1 (N-INT)	LT: B ₂₃ , B ₃₃ , B _{53P} C _{13(X)} , C _{33(X)} , C _{43(X)} , C _{53(X)} , C _{83(X)} , C _{93(X)} TN: C ₁₃ , C ₃₃ , C ₄₃ , C ₅₃ , C ₈₃ , C ₉₃	LT: 0020294228 TN: 0020298096
ThemaFast Condens MA 30-CS/1 (N-INT)	C ₁₃ , C ₃₃ , C ₄₃ , C ₅₃ , C ₈₃ , C ₉₃	0020294233

Remarks:

--